

TESTING RESULTS THROUGH 8/5/2026

Item	Type of Test	Frequency	Completed	Results	Date Scheduled
1	Replacement of HVAC Filters	Tri-Annual	4/1/2026	In Progress	Next service scheduled for August 2026
2	Grease Pit Cleaned and Cleared	Semi-Annual	1/7/2026	In Progress	Service to be scheduled for August 18, 2026
3	Monthly Elevator service	Monthly	7/24/2026	Completed	Service scheduled for 3rd week of the month
4	Industrial Water Treatment testing	Monthly	7/8/2026	Completed	Service scheduled for 1st week of the month
5	High School gym floor refinished	Annual	8/15/2025	In Progress	Service is scheduled for August 18, 2026
6	Pest Control	Monthly	7/16/2026	Completed	Service scheduled for 3rd week of the month
7	Semi-annual state elevator inspection	Semi-Annual	2/25/2026	In Progress	Next inspection is scheduled for August 2026
8	Service and Cleaning of Café & Sports Trainer Ice Machines	Semi-Annual	3/11/2026	Completed	Next service scheduled for September 2026
9	Kitchen Fire Suppression	Semi-Annual	3/11/2026	Completed	Next inspection is scheduled for September 2026
10	Boiler System Service	Annual	9/22/2025	Completed	Service to be scheduled for October 2026
11	Fire Inspection	Annual	10/2/2025	Completed	Inspection to be scheduled for October 2026

12	AHERA Training	Annual	12/22/2025	Completed	Training is scheduled for December 2026
13	Act 39 Water Sampling (Lead)	Annual	1/16/2026	Completed	One location (gym concession stand) exceeded the EPA Action level of 15 ppb. Result was 15.4 ppb. The sink has been turned off for now, as it does not get used. Next sampling will be January 2027.
14	Fire Extinguishers	Annual	1/13/2026	Completed	Service will be scheduled for January 2027
15	AHERA 6-month Surveillance	Semi-Annual	2/12/2026	Completed	Next inspection will be February 2027
16	Stage Inspection	Annual	4/21/2026	Completed	Next inspection is scheduled for April 2027
17	Backflow Prevention Devices - 3 in Link Tunnel; 1 in Stadium	Annual	3/30/2026	Completed	Scheduled for Spring break 2027
18	Backflow Prevention Devices - 1 in playground pit; 1 in stadium pit	Annual	4/15/2026	Completed	Next service scheduled for May 2027
19	Sprinkler System Inspection	Annual	7/7/2026	Completed	Next service scheduled for July 2026
20	Cleaning of Hood/Vent Exhaust System in Kitchen	Annual	7/16/2026	In Progress	Next service scheduled for July 16, 2026
21	Generator Annual Inspection/Fuel Test	Annual	7/27/2026	Completed	Next service scheduled for July 2027
22	Fire Alarm System Test	Annual	7/10/2026	Completed	Next inspection scheduled for July 2026

23	Gym bleachers and aerial inspections	Annual	8/4/2026	Completed	Service to be scheduled for Summer 2027
24	HVAC and Duct Cleaning	Every 5 yrs.	4/2/2026	Completed	Selected units will be inspected July 2027
25	PA State Boiler Inspection	Biennial	8/11/2025	Completed	Next service scheduled for August 2027
26	Stage Curtain - HS Auditorium	Every 5 yrs.	7/28/2022	Completed	Service will be scheduled in 2027
27	Refrigeration PM (walk-in units)	Annual	8/11/2025	Completed	No PM service needed over summer 2026. These units were replaced
28	Radon Testing	Biennial	2/19/2026	Completed	All results are less than the EPA Guideline of 4.0 pCi/l. With three consecutive years of less than 4.0 pCi/L, we will be switching to biennial monitoring. The next round will be scheduled for January 2028
29	Stage Curtain - ES Gym	Every 5 yrs.	1/7/2023	Completed	Service will be scheduled in 2028
30	AHERA 3-year Reinspection	Triennial	8/4/2026	Completed	Next 3-yr inspection is due July 2029.